



ALL APPLIANCE AMPS SHOWN ARE MAXIMUM.
 ALL CIRCUIT WIRE TYPE TH COPPER.
 ALL MATERIALS SHALL BE U. L. LISTED
 AND APPROVED FOR USE INTENDED.
 ALL CONNECTIONS, SUPPORTS AND CONSTRUCTION
 SHALL BE IN ACCORDANCE WITH CA. ADM. CODE
 TITLE 25, CHAPTERS 4600 THRU 4658; ANSI A119.2
 PART III AND APPLICABLE SECTIONS OF NFPA NO.
 70-1975 NEC.

110-VOLT SYSTEM

--- DOTTED LINE INDICATES FACTORY INSTALLED OPTION